

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 3774-0324:104 Page 1 of 1

CATEGORY: Electric Locks

LISTEE: Security Door Controls, 3580 Willow Lane, Westlake Village, CA 91361  
\*Contact: David Geringer (805) 494-0622 Fax (805) 494-8680

DESIGN: Model S7830, S7832, S7850, S7852, Z7830, Z7832, Z7850 and Z7852 electrically controlled single point locks. Units may be followed by suffixes hand orientation, voltage and finish. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12 and 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. Depend on the application, the use of these devices shall be determined by the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as electric locking device for fire-rated swinging doors measuring up to and including 4' wide and 10' high and rated up to 3 h. Authority having jurisdiction should be consulted prior to installation.

\*Rev. 05-15-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 15, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager